State of California Department of Parks and Recreation

NOTICE OF EXEMPTION

TO: Office of Planning and Research

1400 Tenth Street Sacramento, CA 95814 FROM:

Department of Parks and Recreation

1416 Ninth Street P.O. Box 942896

Sacramento, CA 94296-0001

PROJECT TITLE: Water Intake System Repair

LOCATION: San Luis Reservoir State Recreation Area

COUNTY: Merced

DESCRIPTION OF THE NATURE AND PURPOSE OF PROJECT:

Replace approximately 1150 feet of water intake pipe above grade with stabilizing structures at the Basalt Water Treatment Plant within San Luis Reservoir State Recreation Area to comply with current health and safety standards. Pipe segments will be comprised of approximately 100 feet of steel pipe followed by approximately 1040 feet of plastic pipe and end with approximately 10 feet of steel pipe with a well screen. Work will:

- remove and abandon (in place) approximately 1200 ft of pipe; remove and dispose approximately 200 feet of existing pipe, footings, and pump
- replace the pipe access to the vault
- install four concrete piers with excavations approximately 1½ feet by 3 feet and up to 1 foot deep; rod anchors will extend below the concrete an additional 3 feet
- install approximately 85 pre-cast concrete anchors on grade with cable rod anchors approximately 3 feet in depth to select anchors to stabilize
- install water pump inside end of pipe

PUBLIC AGENCY APPROVING THE PROJECT: California Department of Parks and Recreation

NAME OF DIVISION OR DISTRICT CARRYING OUT THE PROJECT: Central Valley District

EXEMPT STATUS:

REASONS WHY PROJECT IS EXEMPT:

Project consists of emergency repairs to publicly owned service facilities necessary to maintain service essential to the public health, safety or welfare.

CONTACT: Emily Ferguson

Northern Service Center

TELEPHONE: (916) 445-8779

EMAIL: eferguson@parks.ca.gov

RECEIVED

JAN 3 0 2008

STATE CLEARING HOUSE

Kathy Amann

Chief, Northern/Southern Service Centers

Acquisition & Development

DATE 1-30-2008